



Patrick A. Thomas
Director of Public Works
Utilities Administration
201 North Broadway, Escondido, CA 92025
Phone: 760-839-4657 Fax: 760-432-9512

September 7, 2005

John Robertus, Executive Officer
Regional Water Quality Control Board
San Diego Region
9174 Sky Park Court, Ste. 100
San Diego, CA 92123-4340

Subject: Tentative Order No. R9-2005-0139; NPDES Permit No. CA0109215: Waste Discharge Requirements for the City of Escondido, Industrial Brine Collection System, Discharge to the Pacific Ocean via the San Elijo Ocean Outfall, San Diego County

Reference Code: POTW:01-1359.02:OTBRY

City of Escondido staff have reviewed the tentative order for the Industrial Brine Collection system and have the following comments:

The maximum discharge for the Goal Line facility should be 80,000 gallons per day. This is their current maximum discharge.

To be consistent with the City's permit for the Hale Avenue Resource Recovery Facility, we request that the semi-annual report be due March 1st.

If you have any questions regarding the above, please contact me at (760) 839-4651.

Sincerely,

Mary Ann Mann
Utilities Manager

cc: Patrick Thomas, Public Works Director
Mark Waggoner, Assistant City Attorney
John Burcham, HARRF Superintendent
Frank Anderson, Deputy Utilities Manager
Vasana Vipatapat, Laboratory Superintendent

2005 SEP -7 P 3:14
SAN DIEGO REGIONAL
WATER QUALITY
CONTROL BOARD